

Suitable for A0 to H120 Fire Rated Module to Module / Deck Seals

The illustrations below detail typical A0 / H120 Firetex skirt seal systems. Methods of attachment may vary in accordance with physical site constraints or choice. In the examples shown, fixing is by M10 stud bolts welded to both bulkhead and deck. Another suitable alternative is to create a stand-off with toe welded steel angle as shown.

Although omitted for clarity, an approved fire rated insulation should be applied over the attachment fittings. Typically, insulation applied to bulkheads and the like would be extended to cover these fixings.

The Firetex system has been independently tested and is certified by Lloyds Register. The double skirt seal, in addition to fire testing to H120 standards, is certified for use in blast conditions up to 1.16 bar g.

Skirts are manufactured to suit and are supplied in straight lengths with ends prepared for joining. Corners, bends and T-pieces may be supplied where required with ends similarly prepared.

