



Notes:

CERTIFICATION: A60 - H120 Lloyd's Register of Shipping, Certificate No. SAS F100054, Blast over-pressure to 1.35 bar g, Lloyd's Register of Shipping Certificate No. LWT 401087/1. (Approvals are also held through other Certifying Authorities, details of which are available upon request).

MOVEMENT: Standard seal construction will accommodate +/-25mm in any plane.

CLIPPING: Each seal is supplied with fitting instructions, adhesive and stainless steel worm drive clips to suit pipe and sleeve diameters. For diameters of 350mm and above 'double clipping' is required. The clipping length or cuff (B) is 50mm for single clips and 75mm for double clips.

Drawing Title:

STANDARD FIRETEX PIPE PENETRATION SEAL SYSTEM A60 - H120 BULKHEAD



Q05151

MCL UNITEX LTD
 MCL House, Adams Close,
 Heanor Gate Industrial Park,
 Heanor, Derbyshire,
 DE75 7SW
 United Kingdom
 Tel: +44 (0)1773 761226
 Fax: +44 (0)1773 711874
 Web: www.mclunitex.com

Rev	Date	Revision detail	Drn	Chk'd	App'd
A	01/06/10	Certification number revised		M.A.T.	J.D. N.R.T.
0	11/06/09	Drawing created		J.D.	N.R.T. I.C.K.
Drawing Number					
PPS-0101					REV A