



Notes:

CERTIFICATION: A0 & H0 Lloyd's Register of Shipping, Certificate No. SAS F100053, Blast over-pressure to 1.35 bar g, Lloyd's Register of Shipping Certificate No. LWT 401087/1. (Approvals are also held through other Certifying Authorities, details of which are available upon request).

MOVEMENT: Standard seal construction will accommodate +/-25mm in any plane.

CLIPPING: Each seal is supplied with fitting instructions, adhesive and stainless steel worm drive clips to suit pipe and sleeve diameters. For diameters of 350mm and above 'double clipping' is required. The clipping length or cuff (B) is 30mm for single clips and 70mm for double clips.

LOCATION: Seal to be fitted on hazard side of deck.

Drawing Title:

STANDARD FIRETEX PIPE PENETRATION SEAL SYSTEM A0 & H0 DECK



MCL UNITEX LTD
 MCL House, Adams Close,
 Heanor Gate Industrial Park,
 Heanor, Derbyshire,
 DE75 7SW
 United Kingdom
 Tel: +44 (0)1773 761226
 Fax: +44 (0)1773 533478
 Web: www.mclunitex.com

Rev	Date	Revision detail	Drn	Chk'd	App'd
C	24/05/11	Location note & sleeve insulation added.	G.F.	M.T.	N.R.T.
B	16/11/10	Cuff sizes altered	M.A.T.	J.D.	N.R.T.
A	02/06/10	Certification number revised	M.A.T.	J.D.	N.R.T.
0	20/09/06	Drawing created	J.D.	N.R.T.	I.C.K.
Drawing Number					