



Notes:

- INSULATION: Jet fire seal clips should be insulated.
- CERTIFICATION: Tested to J120 in accordance with HSE standard OTI 95 634 Lloyd's Register of Shipping, Certificate No. SAS F100066, Blast over-pressure to 1.35 bar g, Lloyd's Register of Shipping Certificate No. LWT 401087/1.
- MOVEMENT: MCL's engineering staff should be consulted for advice.
- CLIPPING: Each seal is supplied with fitting instructions, adhesive and stainless steel worm drive clips to suit pipe and sleeve diameters. For diameters of 350mm and above 'double clipping' is required. The clipping length or cuff (B) is 50mm for single clips and 75mm for double clips.

Drawing Title:

STANDARD JETTEX PIPE PENETRATION
FLEXIBLE SEAL SYSTEM - J120



MCL UNITEX LTD
MCL House, Adams Close,
Heanor Gate Industrial Park,
Heanor, Derbyshire,
DE75 7SW
United Kingdom
Tel: +44 (0)1773 761226
Fax: +44 (0)1773 711874
Web: www.mclunitex.com

Rev	Date	Revision detail	Drn	Chk'd	App'd
B	02/06/10	Certification number revised	M.A.T.	J.D.	N.R.T.
A	04/08/09	Cuff clipping length change	G.F.	N.R.T.	I.C.K.
0	06/10/05	Drawing created	J.D.	N.R.T.	I.C.K.
Drawing Number					
PPS-0410					REV B